



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

DPA/FT.
C/13
7/11
आजादी का
अमृत महोत्सव

No.F6/DFS/MS/School/SZ/2023/ 52

Dated: 01/02/2023

To

The Principal,
S.D.M.C Pratibha Bal Vidyalaya- I/II,
Jasola New Delhi-110025.

Sub:- Regarding renewal of Fire Safety Certificate in respect of **S.D.M.C Pratibha Bal Vidyalaya-I/II, located at Jasola New Delhi-110025.**

Madam,

This has reference to your letter no. MCD/DEO/23/06 dated 16.01.2023 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 16.01.2023 in the presence of Mrs. Noor Afsa, Principal and it was observed that the building which was earlier comprised of 2 blocks having Ground + 2 upper floors each. An additional new block comprised of Ground + 1 upper floor was found constructed. During the inspection following shortcomings was observed:-

1. Hose reel found non functional.
2. Fire pump found non functional.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service

25/1/23

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.