

C/37



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No.F6/DFS/MS/School/WZ/2023/ 53

Dated: 01/02/2023

To,

The Principal,
Vishal Bharti Public School,
A-1, Block, Paschim Vihar,
New Dehli-110063.

Subj: - Regarding renewal of Fire Safety Certificate in respect of Vishal Bharti Public School, Located at A-1, Block, Paschim Vihar, New Delhi-110063.

Sir,

This has reference to your email dated 30.12.2022 on the subject cited above. In this connection, it is to inform you that the above said school building/premises was visited by the officer concerned of this department on 12.01.2023 in the presence of Sh. Naresh (Caretaker) and observed that at present building is comprised of **Ground Floor, 1st Floor, 2nd Floor & 3rd Floor**. However previous FSC was issued to this premise by this department vide letter no. F6/DFS/MS/School/01 dated 01.01.2020 for **Ground Floor, 1st Floor & 2nd Floor only**. This is a case of additions/alterations in the building.

In view of above, renewal of fire safety certificate cannot be considered at this stage & rejected. You are requested to submit revised building plan for the addition of floor duly approved by Building Sanctioned Authority i.e. from MCD/DDA for further necessary action in this matter.

Yours faithfully,

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi-110054.

Dr. OC
24/01/23.