

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/Business/2023/SZ/ 239

Dated: 07/02/2023

To,

Sh. Vinod Kumar Vats (Manager)
Currency Chest, Bank of India, B-19,
Community Centre, Janakpuri, New Delhi-110058.

Sub: - Regarding Fire Audit of Currency Chest by Fire Department at Currency Chest, Bank of India, B-19, Community Centre, Janakpuri, New Delhi-110058.


Sir,

This has reference to your letter No. BOI/JP/CC/VV/2022-23 dated 02/12/2022 on the subject cited above. In this connection, it is stated that the above said premises was inspected by officer concerned of this department on 31/01/2023 from fire safety point of view Sh. Vinod Kumar Vats (Manager) was present at the time of inspection.

During the course of inspection it was observed that the currency chest of Bank of India is comprised of basement only. The occupancy of building is covered under the group "Business Building" Sub Division "E-1" and does not comes under the ambit of Rule-27 (Sub rule-7) of Delhi Fire Service Rules-2010. Hence the Fire Safety Certificate from fire safety point of view is not required. However following fire safety requirements may be provided in the building as per NBC Part-IV:-

1. Fire Extinguishers (as per IS:2190:1992)
2. Hose reels system (as per IS:884:1985)
3. Down comer system (as per IS:3844:1989)
4. Manual Operated Electric Fire Alarm system (as per IS:2189:2008)
5. Over Head Water storage Tank of 15,000 liters capacity for down comer system and for sprinkler system.
6. Terrace pumps of capacity 450 LPM for down comer system & 450 LPM for sprinkler system.
7. Automatic sprinkler system (as per IS:15105:2002) is to be provided in the basement if the area of the basement is more than 200 sq. mtr.

Yours faithfully


(Sunil Chawdhary)
Dy.Chief Fire Officer
Delhi Fire Service

