GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001

No.F6/DFS/MS/WZ /2023 / 207 Dated : 03/02/2023

To,

Executive Engineer (E)/ Elect.
Division-09, 6th floor, DDA Zonal Building,
Near Madhuban Chowk, Rohini,
Delhi-110085.

Sub:- Issuance of Fire Safety Certificate in r/o Community Hall located at CS/OCF-4, Sector-01, Pocket-06, Rohini, Delhi-85.

Sir,

Kindly reference to online e-mail dated 21.11.2022, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **03.01.2023**, in presence of **Sh. Bablu Azad (Electrical)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Fire check door found damaged at some place.
2. 01 fire extinguishers of ABC type provided against the required 10 no's of ABC / Co2 extinguishers.
3. Fire pumps capacity of 2280 lpm provided but not functional.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully

(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel;-01123414250