



75
Azadi Ka
Amrit Mahotsav

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F6/DFS/MS/BP/2023/ 241

Dated: 07/02/2023

To,

The Dy. Director (Admin.)
Indira Gandhi E.S.I. Hospital,
Jhilmil Delhi-110095

Sub:- **Non-Compliance of fire safety Norms in r/o Indira Gandhi E.S.I. Hospital, Jhilmil Delhi-110095.**

Sir,

With reference to above, it is to inform that as per records the aforesaid building does not have valid Fire Safety Certificate as on date. The shortcomings issued vide letter No. F.6/DFS/MS/Hospital/71 dated 12/01/2017 are not yet complied (copy enclosed).

In view of above, it is directed to submit the compliance of requisite Fire Safety Norms to obtain/renew Fire Safety Certificate within the period of two weeks from the issue of this letter. failing which actions such as disconnection of electricity & water supply etc. as per provisions of Delhi Fire Service Act 2007 (Delhi Act 2 of 2009) of Delhi Fire Service Rules 2010 shall be initiated in the interest of public safety.

Yours faithfully

(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to:-

The Medical Superintendent,
Indira Gandhi E.S.I. Hospital, Jhilmil Delhi-110095.

C-146

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001

No. F6/DFs/MS/Hospital/2017/71

Dated 12/01/17

To,

The Dy. Director (Admin.),
Indra Gandhi E.S.I. Hospital,
Jhilmil, Delhi-95.

Sub:- Regarding Issuance Fire Safety Certificate.

Sir,

This is in reference to your letter No.- F.no./DMH/JMW/17/13/2013/ARM/Estate/456 dated 19/10/16 on the subject cited above. In this connection, it is to inform you that the team of officer of this department has carried out the inspection of the above mentioned Hospital from fire safety point of view in presence of Mr. K. P. Panday, Dy. Director (Admin.). During the course of inspection, the following points / shortcomings were noticed in the building comprised of ground plus four upper floors.

1. First Aid Hose reels were not functional.
2. Smoke/heat detectors provided in the building were not functional.
3. Manually operated electric fire alarm were not functional.
4. Public Address system was not functional.
5. Down comer system not functional.
6. Yard hydrant not functional.
7. Both the terrace pumps were non functional.
8. One side entry gate for wards were found locked at all floors. It shall be kept open at all times.

In view of above, the building can not be considered for grant of fire safety certificate. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully

VK
10/1

(Vipin Kental)
Chief Fire Officer

o/e

Copy to:-

The Medical Superintendent,
Indra Gandhi E.S.I. Hospital,
Jhilmil, Delhi-95.