

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/SZ/2022/ 3139

Dated: 15/12/2022

To,
The Authorized Signatory,
The K.M CGHS Ltd.
Plot No 12, Sector - 12, Dwarka,
Phase - 1, New Delhi - 110078

Subject: Renewal of Fire Safety Certificate in r/o The K.M CGHS Ltd. Located at Plot No 12, Sector - 12, Dwarka, Phase - 1, New Delhi - 110078.

Sir,

Please refer to your Email dated 30/11/2022 on the subject mentioned above. In this connection it is to inform you that the premise was re-inspected by the officer concerned from this department on 06/12/2022 in the presence of Sh. Jay Narayan (Manager) from fire safety point of view.

During the course of inspection following shortcomings have been observed

1. Only one fire extinguishers of ABC type 5Kg capacity is found provided against requirement of two fire Extinguishers at each floor.
2. Hose reels & Hydrant system found nonfunctional
3. PA System found Nonfunctional.
4. Hose boxes with hoses & branches are not provided at some places.
5. Terrace Pump of 450 lpm with 40m head found nonfunctional .
6. Exit signage found removed at some places.

In view of the above, fire safety certificate cannot be renewed. You are advised to rectify the above said shortcomings under intimation to this department for further necessary action.

Yours faithfully,


(Arul Garg)
Director
Delhi Fire Service

Copy to:-

1. Joint Director, DDA, Vikas sadan, INA, New Delhi