

C/57

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F-6/DFS/MS/2023/WZ/ 205

Dated: 03/02/2023

To,

Sh. Hukum Chand Deshwal,  
The Retreat Motel/ Resort,  
Alipur, Main G.T.K. Road, Delhi-110036.

**Sub:- Renewal of Fire Safety Certificate in respect of The Retreat Motel/ Resort located at Alipur, Main G.T.K Road, Delhi-36.**


Sir,

Please refer to your M.H.A application ID No. 2023010700225 dated 07/01/2023 on the subject cited above. In this connection it is to inform you that the premise was visited by officer concerned of this department on 20.01.2023 in presence of Sh. Anil Bhardwaj to verify the fire safety arrangements installed. Your request for renewal of Fire Safety Certificate is rejected under sub rule (3) of Rule 37 of Delhi Fire Service Rules 2010, due to following shortcomings.

1. Fire check door found removed.
2. Fire Extinguishers found not functional.
3. First-Aid hose reel found not functional.
4. Smoke/ Heat detectors found not functional.
5. MOEFA found not functional.
6. Internal Hydrants found not functional.
7. Terrace level pump found not functional.
8. Exit signage's found removed.

You are requested to apply again after compliance of the above mentioned shortcomings for further consideration in this matter.

Yours faithfully

  
(Dharampal Bhardwaj )  
Dy. Chief Fire Officer  
WEST ZONE

Copy to-

1. The Joint Commissioner of Police, First Floor, Police Station Defence Colony, New Delhi-110049.