

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

c/62

No.F6/DFS/MS/GH/NDZ/ 53

Dated: 01.02/2023

To,
The Manager,
M/S **3BS Houses**, Guest House,
F 31, 32, D.B.G Market,
Karol Bagh, New Delhi.

Sub: Regarding renewal of FSC in r/o M/S 3BS Houses Guest House, F 31, 32, D.B.G Market, Karol Bagh, New Delhi. (Id no. 2023010700245 dated 20/01/2023).

Sir,

This has reference to your online ID No. 2023010700245 dated 20/01/2023, on the subject cited above. In this regard, it is to inform you that the site was visited by the officer concerned of this department on dated 23.01.23 in presence of **Manager** and following shortcomings were observed:

1. Smoke management & CO detectors are not installed as per gazette notification 27.05.2019.
2. PA system found nonfunctional.
3. The building plan of all floors is also not submitted by owner/occupier.

In view of above, FSC cannot be renewed. Therefore you are requested to rectify the above shortcomings for further consideration in the matter.

Yours faithfully,



(S. K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service



Copy to :-

1. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.