

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO F-6 DFS MS EH 2023 SZ 66

Dated: 07/02/2023

To

The Dy. Health Officer, (MCD)
Public Health Officer, (Green Park Zone)
Aurobindo Marg, Green Park, Delhi 110016

Sub: - Regarding issuance of fire safety certificate in r/o M/s Bengali Sweet, Corner located at G-19, South Extension, Market Part-1, New Delhi 110049.


Sir,

This has reference to your **MHA Portal ID 2022122421797 dated 26/12/2022** on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 24.01.2023 in the presence of Mr. Rajesh Jain to verify the fire safety measures installed in the building and observed that the restaurant running at GF Floor only. During inspection, following points were observed:

1. The internal Staircase need to be segregated at ground level.
2. Overhead tank capacity 12,000 ltrs provided against the required capacity of 20,000 ltrs.
3. Exit Signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(Virender Singh)
Chief Fire Officer (HQ)
Delhi Fire Service
