

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/2023/SZ/ 68

Dated:- 07/02/2023

To

The Dy. Health Officer, (MCD)  
Public Health Officer, (Green Park Zone)  
Aurobindo Marg, Green Park, Delhi 110016

**Sub:** - Regarding issuance of fire safety certificate in r/o M/s BIG WONG Hospitality Pvt Ltd, located at FF, M-61, M Block Road, Greater Kailash-II, New Delhi 110048.


Sir,

This has reference to your MHA Portal No. 2023010600168 dated 06/01/2023 on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 24.01.2023 in the presence of Mr. Kulwant Singh to verify the fire safety measures installed in the building and observed that the restaurant running at First Floor only. During inspection, following points were observed:

1. There are two staircases having width of 1.0 mtr each against the required width of 1.50 mtr each respectively.
2. There are two exit doors having width of 1.0 mtr each against the required width of 1.50 mtr each respectively.
3. First aid hose reel not provided.
4. The MOEFA system not provided.
5. Internal hydrant not provided.
6. Terrace level pumps capacity 450 LPM not provided.
7. Overhead tank capacity 20,000 ltrs not provided.
8. Exit Signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

  
(Virender Singh)  
Chief Fire Officer (HQ)  
Delhi Fire Service

S/O