

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/GH/2023/SZ/ 57
To

Dated: 06.1.02..2023

The Addl. Commissioner of Police,
Lic/Branch, 1st Floor, P.S Defence Colony
New Delhi 110049.

Sub: Regarding renewal of FSC in r/o M/s BMK Guest House, B-2, Greater Kailash Enclave-1,
New Delhi 110048


Sir,

This has reference with MHA Portal ID 2023010400096 dated 12/01/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 25.01.2023. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Fire check doors not provided in the building as per clause 7.31 of UBBL 2016.
2. First aid hose reel provided but not functional.
3. Automatic sprinkler system non functional.
4. Internal hydrant non functional.
5. Terence level fire fighting pump not functional.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE



Copy to:-

1. M/s BMK Guest House, B-2, Greater Kailash Enclave-1, New Delhi 110048