

C/12

C/13

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**



No. F6/DFS/MS/School/WZ/2022/ 62

Dated: 03/02/2023

To,
The Principal,
Merry International Sr. Sec. Public School,
Block-H-9, Sector-07, Rohini,
Delhi-110085.

Sub: Issue of FSC in r/o Merry International Sr. Sec. Public School, Block-H-9, Sector-07, Rohini, Delhi-110085.

Sir,

This is in reference to your letter No. nil dated nil received through outdoor diary no. 8622 dated 29.11.2022 on the subject cited above. The premise was inspected by the concern nominated authority of this department on **28.12.2022**, in presence of **Mr. Manish Kathuria** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Terrace Fire pump with capacity 450 LPM found but detached from water line.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/htt
p://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms

Yours faithfully

**(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel;-01123414250**

DL
my