

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/EH/2023/SZ/ 63

Dated: 07/02/2023

To,

The Manager,
M/s Sandoz Restaurant Pvt. Ltd,
B-1/631, Main Najafgarh Road,
Janakpuri, New Delhi-110058.

Sub: - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o M/s Sandoz Restaurant Pvt. Ltd, B-1/631, Main Najafgarh Road, Janakpuri, New Delhi-110058.


Sir,

Please refer to your ID No. 2022122021550 dated 20/12/2022 on the subject cited above. In this connection this is to inform you that officers concerned of this department inspected the school on 31/01/2023 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Sh. Ram Singh (Manager) was present and it was observed that the restaurant building is comprised of basement (storage/office), stilt floor (parking), upper ground floor (restaurant), first floor (banquet hall), and second floor (not in use) but restaurant is running at upper ground floor only and have following shortcomings.

1. Fire check doors found removed.
2. One no. First aid hose reel found removed.
3. MOEFA provided but not functional.
4. Down comer system provided but not functional.
5. Terrace pump having 900 lpm provided but not functional.
6. Overhead tank capacity 20,000 liters provided but domestic connection also draws from OHT.
7. Exits signages are not sufficient.

Keeping in view of above, the building cannot be considered for issuance of fire safety certificate, at this stage. Therefore you are advised to rectify the above said shortcomings under the intimation to this department for further course of action.

Yours faithfully


(Virender Singh)
Chief Fire Officer
Delhi Fire Service
904

Copy to:-

The Joint Commissioner of Police, Licensing Unit, First Floor, Police Station, Defence Colony, New Delhi.