

C/60

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2023/ 63

Dated: 06/02/2023

To,

The Principal ,<skvsector1@gmail.com >
Sarvodaya Kanya Vidhalaya, Block 1, 3 & 4
Pocket – 7, Sector – 1, Dwarka,
New Delhi – 110045.

Subject: Issuance of Fire Safety Certificate in r/o Sarvodaya Kanya Vidhalaya, Block 1, 3 & 4
Located at Pocket – 7, Sector – 1, Dwarka, New Delhi – 110045.(School ID-1821030)

Sir,

Please refer to your Email dated-10/01/2023 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 20/01/2023 in the presence of Mrs. Mary Gemma Lakra (HOS).


During the course of inspection following shortcomings are observed.

1. Hose reel hose found nonfunctional.
2. Terrace pump found nonfunctional.
3. Overhead tank of capacity 10,000 ltr found empty.
4. Exit Signage not provided at appropriate places.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,


(Anu Garg)

Director

Delhi Fire Service


31/2/23

Copy to:-

1. Directorate of Education Old Secretariat Delhi – 110054.