

c/91

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/GH/NDZ/64

Dated: 07/02/2023

To,

The Manager,  
M/S **Shiv Dev International**,  
8518-22, A.K. Road, Pahar Ganj,  
New Delhi.

**Sub: Regarding renewal of FSC in r/o M/S Shiv Dev International located at 8518-22, A.K. Road, Pahar Ganj, New Delhi.**

Sir,

This has reference to your Online 2023011700661 dated 17/01/2023, on the subject cited above. In this regard, it is to inform you that the site was visited by the officer concerned of this department on dated 24.01.23 in presence of **Mr. Ajay Kumar** and following shortcomings were observed:

1. Fire Check doors are not installed as per gazette notification 27.05.2019.
2. Smoke management is not installed as per gazette notification 27.05.2019.

In view of above, FSC cannot be renewed. Therefore you are requested to rectify the above shortcomings for further consideration in the matter.

Yours faithfully,

  
07/02/23  
(S. K. Dua)

Dy. Chief Fire Officer  
Delhi Fire Service

**Copy to :-**

1. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.