

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

C/96

No. F.6/DFS/MS/^{G/M}Hotel/2023/SZ/ 67
To

Dated: 07/...02/2023

The Joint Commissioner of Police,
Lic/Branch, 1st Floor, P.S Defence Colony
New Delhi 110049.

Sub: Regarding renewal of FSC in r/o M/s The Muse Sarovar Portico (Palm Land Hotel & Resorts LLP) Plot No 88-89, Bijwasan Road, Kapashera, New Delhi 110037


Sir,

This has reference with MHA Portal ID 2022111420181 Dated 15/11/2022 on the subject cited above. In this connection, it is to inform you that the premise was inspected by officers concerned of this department on 28.01.2023 to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation

1. Fire check doors not provided in the building as per clause 7.31 of UBBL 2016.
2. Carbon Monoxide detector not provided as per clause 7.31 of UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE

