

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/2023/SZ/ 70

Dated:- 07/10/2023

To

The Dy. Health Officer, (MCD)
Public Health Officer, (Green Park Zone)
Aurobindo Marg, Green Park, Delhi 110016

Sub: - Regarding issuance of fire safety certificate in r/o M/s Third Wave Coffee (Unit of Heisetasse Beverages Pvt Ltd, located at GF & Mezzanine Floor, M-44, M Block, Greater Kailash-II, New Delhi 110048.


Sir,

This has reference to your MHA Portal No. 2022100718754 dated 07/10/2022 on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 24.01.2023 in the presence of Mr. Saurabh (Manager) to verify the fire safety measures installed in the building and observed that the restaurant running at GF & Mezzanine Floor only. During inspection, following points were observed:

1. There is one staircase having width of 1.50 mtr against the required two staircases having width of 1.50 mtr & 0.92 mtr respectively.
2. Exit Signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully



**(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)**

o/n