



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/EH/2023/SZ/ 83
To

Dated: 15.02.2023

The Dy. Health Officer, (South Zone)
Public Health Department, MCD,
Green Park, Zone, New Delhi 110016

Sub: Regarding issuance of FSC in r/o M/s WENDYS (A unit of Sierra Nevada Restaurants P Ltd)
Plot No H1A, GF & FF, Zorawar Tower Kalkaji New Delhi-110019.



Sir,

This has reference with MHA Portal ID 2022122221687 dated 22/12/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 03.02.2023 in the presence of Ms. Geeta Rani (Manager) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. There are two Staircases having widths of 1.50 mtr & 1.45 mtr against the required width of 1.50 mtr each as per UBBL-2016.
2. There are two exits having width of 1.45m & 1m at ground floor and 1.45m & 1.50m at First Floor against the required width of 1.50 mtr each as per UBBL-2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,


14/2/2023
(Virendra Singh)
Chief Fire Officer (HQ)
Delhi Fire Service


Copy to:-

1. M/s WENDYS (A unit of Sierra Nevada Restaurants P Ltd) Plot No H1A, GF & FF, Zorawar Tower Kalkaji New Delhi-110019.