



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No F6/DFS/MS/SZ/2023/ 306

Dated 15/02/2023

To,

Col. BMR Mehta (Retd.)  
Auditorium building/community hall,  
foot ball house sector-19,  
Dwarka, New Delhi.

**Subject: Renewal of Fire Safety Certificate in r/o Foot ball house sector-19 Dwarka New Delhi.**

Sir,

Please refer to letter No- AIFF/ADMIN/FIRE/2023/1217 dated-24/01/2023, on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned of this department on 08/02/2023.

**The following shortcomings were observed:**

1. All the exits/ passage & corridors must be clear from any obstruction.
2. Smoke exhaust system found nonfunctional in basement.
3. First – Aid Hose Reels found nonfunctional.
4. Automatic Sprinkler System found nonfunctional in basement.
5. Internal Hydrants found nonfunctional.
6. All the Pumps provided at ground level & terrace level found nonfunctional except jockey pump. All the pumps must be kept functional in auto mode.
7. Pressurization system in Lift shaft found nonfunctional.
8. Lift signage found not provided.
9. Exit signage found removed.
10. Floor plans found not provided.

Hence renewal of Fire Safety Certificate cannot be considered at this stage and you are advised to rectify the aforesaid shortcoming under intimation to this department for further consideration in this matter.

Yours faithfully,

(Sunil Chaudhary)  
Chief Fire Officer,  
Delhi Fire Service.

15/02/23  
15/2

Copy to; - The Vice Chairman, DDA, INA Vikas Sadan, New Delhi-110023.