

C/7
C/9

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/Restaurant/2023/ 82
To,

Dated: 14/02/2023

Mr. Kumar Gaurab,
House No.N-406, Park Elite Primium,
Sector-84, Kheri, Kalan 113,
Faridabad, Haryana-121002.

Sub: Issue of FSC in r/o M/s Chinese Wok, (A unit of Lenexis Food Works Pvt. Ltd.) Unit No.12, Ground floor, Plot No.6, G3S Cinema, Garg Trade Centre, Sector-11, Rohini, Delhi-85.
Sir,

This is reference to online application no. 2022120120935 dated 02.12.2022, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **27.01.2023**, in presence of **Miss. Ahana (Senior Asst. Manager)** to ascertain the availability and operability of the fire prevention and fire safety measures. The following shortcomings were observed:

1. Alternate exit door of 1.50 mtr is not provided.
2. The Smoke management system in restaurant not provided.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 it is advised the applicant to apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms

Yours faithfully


13/21/2023
(Virendra Singh)
Chief Fire Officer


