

GOVERNMENT OF NATIONAL CAPITAL TERRITOTY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/2023/SZ/ 30/

Dated: 15/ 02 /2023

To

For Hans Raj Sachdeva, Building at Plot No A-54, FIEE Complex, Okhla Industrial Estate, Phase-II, New Delhi 110020

Sub: - Regarding issuance of Fire Safety Certificate in r/o Building at Plot No A-54, FIEE Complex, Okhla Industrial Estate, Phase-II, New Delhi 110020.

Sir,

This has reference to with Outdoor diary no 9836 dated 09/01/2023 on the subject above. In this connection, it is to inform you that the premise was inspected by the concern nominated authority of this department on 03/02/2023 in the presence of Mr. Nabi Jaan to check the compliance of fire safety arrangements from fire safety point of view and following shortcomings were observed:

1. There are two Staircases having width of 1.25 mtr & 1.35 mtr against the required width of 1.50 mtr each respectively

2. There are two doors having width of 1.25 mtr & 1.35 mtr against the required width of 1.50 mtr each respectively

3. Fire check doors not provided in the building.

- 4. Smoke management system not provided in basement.
- 5. First aid hose reel provided but not functional
- 6. Automatic sprinkler system provided but not functional
- 7. Internal hydrant and yard hydrant provided but not functional.
- 8. Electrician Fire Pump capacity 2280 LPM, Diesel Engine Pump 2280 LPM and Jockey Pump 180 LPM not provided.
- 9. Terrace level pumps capacity 450 LPM not provided.
- 10. Underground tank capacity 1, 00,000 ltrs found empty.
- 11. Overhead tank capacity 10,000 ltrs not provided.
- 12. Exit Signage not provided.
- 13. Standby power supply not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(Virendfa Singh)
Chief Fire Officer (HQ)
Delhi Fire Service