

c/17

c/18



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/2023/ 84

Dated 15/02/2023

To

The Dy. Health Officer, South Zone,
Public Health Department, MCD,
Aurobindo Marg, Green Park,
New Delhi 110016.

Sub: - Regarding issuance of fire safety certificate in r/o M/s METACAFE Food Pvt. Ltd at First Floor, Property No 57, Basant Lok Market, Vasant Vihar, New Delhi – 110057

Sir,

This has reference to with MHA Portal ID 2022071414615 dated 15/12/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 07.02.2023 in the presence of Mr. Amit Kumar (Supervisor) to verify the fire safety measures installed in the building and the following points were observed:

1. There are two staircase having width of 1.35m & 1.30m (not continues upto 1st floor) against the required width of 1.50 mtr each respectively as par UBBL -2016.
2. Exit signature not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

14/2/2023

(Virendra Singh)
Chief Fire Officer (HQ)
Delhi Fire Service

Copy to:

1. The Joint C P (Lic/Branch) 1st Floor, P.S. Defence Colony, New Delhi 110049