



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/10  
महेश मिश्रा  
अभिधीनता

NO. F-6/DFS/MS/2023/School/ 84

Dated 20/02/2023

To,

The Principal  
Mahavir Senior Model School  
Sangam Park Ext., Rana Pratap Bagh,  
GTK Road, Delhi-110033.

Sub: - Regarding issuance of fire safety certificate in r/o Mahavir Senior Model School at Sangam Park Ext., Rana Pratap Bagh, GTK Road, Delhi-110033.

Sir,

Please refer to your letter No. Nil dated 31.01.2023 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 12.01.2023 at the time of inspection Sh. Mahesh Mishra (Care Taker) was also present at site. During the course of the inspection it is observed that the building is comprised of Ground & 03 upper floors only. Your request for FSC is rejected under Rule 37 (3) due to following shortcomings.

- 1 Fire extinguishers provided in the school building but non functional.
- 2 Hose reel hose provided but not functional. Hose reel hose & some nozzle are found missing.
- 3 Internal hydrant provided but not functional.
- 4 Terrace level fire pumps capacity of 450lpm x2 provided but found not functional.
- 5 Exit signage's found removed in the school building.

Keeping in view of above, fire safety certificate cannot be considered at this stage

Yours faithfully

(Dharpal Bhardwaj)  
Chief Fire Officer  
Ph:-011-23414250

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.