



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6/DFS/MS/2023/BP/ 33

Dated: 06/02/2023

To,

Ms. Rashmi Bhardwaj
Dy. Chief Architect
Delhi Metro Rail Corporation
Metro Bhawan, Fire Brigade Lane,
New Delhi - 01

Subject: Regarding approval of building plans from fire safety point of view in r/o construction of elevated Metro Station at Khanpur, New Delhi.

Sir,

Please refer online reference No. DMRC/Fire/78/2023/01/311 dated 31.01.2023 and a letter submitted by Chief Architect vide No. DMRC/12/CA/DCDD-02/DFS/001 dated 25.01.2023 on the above cited subject. In this connection, this is to inform you that the matter was examined and observed that the shortcomings issued vide this office letter No. F.6/DFS/MS/2023/BP/14 dated 19.01.2023 are not yet complied.

Accordingly, the case is rejected.

Yours faithfully

(Atul Garg)
Director

011 23414000

Copy to:

Ms. Papiya Sarkar, Chief Architect,
Delhi Metro Rail Corporation
Metro Bhawan, Fire Brigade Lane,
New Delhi - 01

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6/DFS/MS/2023/BP/ 14

Dated: 19/01/2023

To,

Ms. Rashmi Bhardwaj
Dy. Chief Architect
Delhi Metro Rail Corporation
Metro Bhawan, Fire Brigade Lane,
New Delhi - 01

Subject: Regarding approval of building plans from fire safety point of view in r/o construction of elevated Metro Station at Khanpur, New Delhi.

Sir,

Please refer online reference No. DMRC/Fire/78/2023/01/306 dated 05.01.2023 on the above cited subject. In this connection, this is to inform you that the matter was examined and observed that there is an online proposal for construction of Metro Station at Khanpur, New Delhi. The following shortcomings are observed:

1. All around 06 meter wide motorable road with 09 m turning radius for fire tender movement is not clearly shown on the plans as per clause 8.2 of UBBL 2016.
2. Width of corridor is not 2.0 m in FOB paid area.
3. No exit is proposed for paid FOB corridor.
4. Exits are not proposed as per annexure J 5.2 (b) of NBC 2016 part 4 at concourse level.

Accordingly, the building plans are rejected herewith.

Yours faithfully

(Atul Garg)
Director

011 23414000

