

c/7

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F-6/DFS/MS/2023/WZ/ 81

Dated: 20/02/2023

The Joint Commissioner of Police (Lic.)
1st Floor, Licensing Unit, Police Station,
Defence Colony, Delhi-110049.

Sub:- Regarding Issuance of Fire Safety Certificate in respect of M/s Hotel Family Guest House Located at Property No. 81/96, Village Bakoli, Delhi-36.

Sir,

Please refer to online application 2022110519815 dated 15.01.2023 on the subject cited above. In this connection it is to inform you that above said Guest House building has been inspected by the officers concerned of this department from Fire Safety point of view on 03.02.2023 in the presence of Sh. Sunil Chauhan. During inspection it has been observed that said building is comprised of Ground+03 upper floors.

The following shortcomings have been observed:

1. All exit doors should be openable outwards .
2. Width of corridor is 1.50 m against required width of 1.80m.
3. Carbon Monoxide detectors are not provided in guest room at all upper floors.
4. Exit Signs are not provided.

In view of the above shortcoming, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


Atul Garg
Director

Delhi Fire Service



Copy to:-

1. M/s Hotel Family Guest House, 81/96 Village Bakoli, Delhi-36.