

c/31

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/SZ/2023/ 88

Dated:- 17/02/2023

To.

The Owner/Occupier
M/s. Nasheman Bar (Counsul Nature Elements Pvt. Ltd.),
C-48, GF, Community Centre, Industrial Area,
Phase- 1, Naraina, New Delhi- 110028.

Sub: - Regarding issuance of fire safety certificate in r/o M/s. Nasheman Bar (Counsul Nature Elements Pvt. Ltd.) located at C-48, GF, Community Centre, Industrial Area, Phase- 1, Naraina, New Delhi- 110028.

Sir.


Please refer to your online application ID 2023011200474 dated 13.01.2023, on the subject cited above. In this connection, it is to informed you that the said eating house running at ground floor of a building comprised of basement, ground plus three upper floors. In this connection it is to inform you that the above said assembly building (Restaurant) was inspected by the officers concerned of this department from safety point of view on 23.01.2023 in presence Sh. Kundan, Receptionist of the restaurant.

During the course of inspection it has been observed that fire safety arrangements such as MOEFA, fire extinguishers etc. found provided, However the following shortcomings have been observed:-

- 1 Smoke ventilation found not provided.
- 2 First Aid hose reel found non functional.
- 3 Internal hydrant system found not provided.
- 4 Terrace Fire Pump capacity of 450 LPM is found provided but not functional.
- 5 Overhead water Tank capacity 5,000 lts found provided against required capacity of 20,000 lts.
- 6 Exit signages found not provided.

Keeping in view of above, fire safety certificate cannot be considered at this stage. You are requested to rectify the above said shortcomings for taking further necessary action in this matter.

Yours faithfully


(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Executive Engineer (Building), MCD, Karol Bagh Zone, Anand Parbat, New Delhi.