

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

NO F.6/DFS/MS/2023/SZ/ 324

Dated 30 / 02 / 2023

To

Mr. Rajiv Chawla,
Chawala House, 19, Nehru Place,
New Delhi 110019

Sub: Regarding issuance of Fire Safety Certificate (FSC) in r/o Chawala House at 19, Nehru Place, New Delhi 110019.

Sir,

This has reference with Email of dated 04/02/2023 on the subject cited above. In this connection, this is to inform you that requisite reply has already been furnished vide this department letter of even no 252 dated 08/02/2023 (Copy of this said letter is enclosed for your ready reference)

This is for your information and action at your end please.

Yours faithfully

(SUNIL CHAWDHARY)
CHIEF FIRE OFFICER (SZ)
DELHI FIRE SERVICE

o/c

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/2023/SZ/ 252

Dated: 08/02/2023

To

Mr. Rajiv Chawla,
Chawala House, at 19,
Nehru Place, New Delhi 110019.

Sub: Regarding Renewal of Fire Safety Certificate in r/o M/s Chawala House, at 19, Nehru Place,
New Delhi 110019.



Sir,

This has reference with Email of Dated 05-12-2022 on the subject cited above. In this concretion it is to inform you that the premise was inspected by the concern officers of this department on 25-01-2023 & observed that the building is comprised of Basement, and Five upper floors. During the course of inspection, the following shortcoming observed were noticed:-

1. Fire check door found removed.
2. Public address system found removed.
3. Exit sign found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


8/21/2023
(Virendra Singh)
Chief Fire Officer (HQ)
Delhi Fire Service


Copy to: -

1. The Executive Engineer (Bldg) South MCD, Dr. SPM Civic Center, Minto Road, New Delhi 110002