

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/WZ/2023/ 345

Dated: 22/02/23

To,

Sh. Raj Kumar,
House No.12 25, Ward No.19,
Hari Nagar, Rohtak,
Haryana-124021.

Sub: Issue of FSC in r/o Royal Bhawan, Two Wings Welfare Society, Block-A, Sector-15, Rohini, Delhi-110085.

Sir,


Kindly reference to online application No.2023011000357 dated 16.01.2023, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 27.01.2023, in presence of **Sh. Puneet Chopra (Manager)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Fire check door is not provided in basement.
2. Smoke management /ventilation are not provided.
3. Ground level fire pump 2 x 450lpm provided required capacity of one electric, one D.G. pump capacity of 2280 LMP & one jockey pump capacity 180 LMP not provided.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms

Yours faithfully


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel;-01123414250

all
OK