

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F.6/DFS/MS/2022/ 2415

Dated: 21/09/2022

To,

The Authorized Signatory,  
Videocon Tower (Videocon Industries Limited),  
E-1 Jhandewalan Ext., New Delhi.

**Sub:- Renewal of Fire NOC in r/o Videocon Tower (Videocon Industries limited ) Block -  
E1, Jhandewalan Ext, New Delhi.**

Sir,

This has a reference to your letter No. Nil dated 22/08/2022 on the subject cited above. In this regards, it is to inform you that the site was inspected by the officers concerned department on 09/09/2022 in the presence of Maintenance Manager and the following shortcomings are still not complied.

1. Fire check door found removed from lift lobby and from corridor provided for compartmentation.
2. Detectors found nonfunctional at some offices .
3. Repeater panel found nonfunctional.
4. Lift lobby found encroached by making a reception and offices.
5. Pressurization system of lift shaft & lobby and staircase found nonfunctional.
6. P.A. system provided but not functional at some places.
7. Branches of tree are required to be pruned for freely movement of fire tender all around the building.

In view of above, the application for renewal of fire NOC is rejected. Further, it is informed that the occupancy in the building in absence of requisite fire & life safety arrangements, shall be at risk and liability of the owner/occupier . The statutory /licensing authority may take suitable action as deemed fit .

Yours faithfully

(Atul Garg)  
DIRECTOR

Delhi Fire Service  
Ph. 011- 23414000