

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F6/DFS/MS/2023/SZ/ 394  
To

Dated: 01 / 03 / 2023

Mr. J.K Jain (Director)  
Plot No. B-6/8, Okhla Industrial Area,  
Phase-II, New Delhi – 110020

**Sub:** - Regarding issuance of Fire Safety Certificate in r/o Building at Plot No. B-6/8, Okhla Industrial Area, Phase-II, New Delhi – 110020


Sir,

This has reference to with Outdoor diary no 9840 dated 09/01/2023 on the subject above. In this connection, it is to inform you that the premise was inspected by the concern nominated authority of this department on 21/02/2023 in the presence of Mr. J.K Jain to check the compliance of fire safety arrangements from fire safety point of view and following shortcomings were observed:

1. Fire check doors found removed.
2. Smoke management system not functional in the building.
3. First aid hose reel provided but not functional
4. Automatic sprinkler system provided but not functional
5. Internal hydrant and yard hydrant provided but not functional.
6. Discharge of main Fire Pump capacity 2280 LPM not functional.
7. Terrace level pumps capacity 900 LPM provided but not functional.
8. Overhead tank capacity 20,000 ltrs provided and the fire tank is also being used for domestic purposes.
9. Exit Signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

  
(SUNIL CHAWDHARY)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

Copy to:-

1. The Executive Engineer (Bldg Department) Central Zone, Jal Vihar Lajpat Nagar, New Delhi 110024