



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

70
आज़ादी का
अमृत महोत्सव

No. F6 /DFS/MS/Hospital/SZ/2023/ 413

Dated: 01/03/2023

To

The Medical Superintendent,
M/s Dr. B.R. Ambedkar Institute of Rotary Cancer,
AIIMS Complex, Ansari Nagar,
New Delhi-110029.

Sub: - Regarding renewal of Fire Safety Certificate in r/o **M/s Dr. B.R. Ambedkar Institute of Rotary Cancer, AIIMS Complex, Ansari Nagar, New Delhi-110029.**

Sir,

This has reference to the email dated 09.07.2022 on the subject cited above, it is informed that the said building was inspected by a team of officers concerned of this department on 13.02.2023 in the presence of Mr. Naresh Kumar Yadav (Security Officer) & Mr. Ashok Sharma (Fire Officer) and it was observed that the building is comprised of Basement + Ground + 07 upper floors. During the inspection the following shortcomings were observed:

1. One of the staircases leading to the terrace was not segregated from the lift lobby.
2. Some fire check door (FCD) found non functional.

In view of above shortcomings, the application for renewal for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)
Director

Delhi Fire Service

रि. 06
27/2

Copy to:-

1. Sh. Pradeep Kumar, Executive Engineer (E), 203, 2nd Floor Admin Block, AIIMS, New Delhi-110029.