

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No.  
To

F.6/DFS/MS/GH/2023/SZ/ 94

Dated: 28.1.22./2023

The Addl. Commissioner of Police,  
Lic/Branch, 1<sup>st</sup> Floor, P.S Defence Colony,  
New Delhi 110049.

Sub: Regarding renewal of FSC in r/o M/s Hotel Swapnil International at RZA-43, NH-8, Mahipalpur Extn., New Delhi 110037

Sir,

This has reference with MHA Portal ID 202301030086 dated 05/01/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 20.02.2023. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Fire check doors not provided in the building as per clause 7.31 of UBBL 2016.
2. Smoke management system not provided in the building as per clause 7.31 of UBBL-2016.
3. Carbon Monoxide detector not provided as per clause 7.31 of UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(SUNIL CHAWDHARY)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

Copy to:-

1.M/s Hotel Swapnil International at RZA-43, NH-8, Mahipalpur Extn., New Delhi 110037