

C/17

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/WZ/School/2023/96

Dated: 27/02/2023

To,

The Manager,
Pole Star Public School,
Sector-2, Rohini,
Delhi-110085.

Sub: Issue of FSC in r/o Pole Star Public School, Sector-2, Rohini, Delhi-110085.


Sir,

This is in reference to your letter No. nil dated 15.12.2022 received through outdoor diary no. 9162 dated 15.12.2022 on the subject cited above. The premise was inspected by the concern nominated authority of this department on **16.02.2023**, in presence of **Mr. Sunil (Caretaker)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Alternate iron staircase of 1.20 mtr is found removed in basement.
2. First Aid hose reel provided but not functional.
3. Sprinkler system provided but not functional in basement.
4. Smoke Management System upper floor or basement not provided.
5. Terrace Fire pump with capacity 450lpm & 180lpm jockey pump provided but not functional.
6. Overhead fire water tank capacity 5000ltr found empty.
7. Exit signage not provided.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms

Yours faithfully



(Dhrampal Bhardwaj)

Chief Fire Officer

Tel:-01123414250

OR
94