

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/School/2023/SZ/ 103
To

Dated: 01/03/2023

The Principal,
SDMC Primary (Co-ed) School,
Sector -4, Pushp Vihar,
New Delhi 110017

Sub: Reg. renewal of Fire Safety Certificate in r/o SDMC Primary (Co-ed) School, Sector -4, Pushp Vihar, New Delhi 110017

Sir,

This has reference with your Outdoor diary no 10551 dated 27/01/2023 on the subject cited above. In this regard, it is to inform you that the school premises have been inspected by officer concerned of this department on dated 16.02.2023 in presence of Mrs. Victoria Lugun (Principal) to verify the status of existing fire prevention and fire safety measures. During the course of inspection, the shortcomings observed are as below;

1. The First Aid hose reels provided but not functional.
2. The terrace level fire fighting pumps capacity 450 LPM provided but not functional.
3. The exit Signage found removed at some place.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(SUNIL CHAUDHARY)
CHIEF FIRE OFFICER

Copy to: -

1. The Director of Education, South MCD, Civic Center Minto road, New Delhi 110002