



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

No. F-6/DFS/MS/EH/2023/ 95

Dated 28/02/2023

To

The Ministry of Home
Affair Portal.

Sub: - Regarding issuance of fire safety certificate in r/o M/s Kayree (A Unit of Foreshore Hospitality Pvt. Ltd.) located at 2nd & 3rd floors, Plot No.03, LSC Gujrawala Town, Part-I, Delhi-110009.


Sir,

This has reference to your online I.D. No. 2023010700210 Dated: 23.01.2023 on the subject cited above. In this connection this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 07.02.2023 in the presence of Mr. Geetanshu to verify the fire safety arrangements as stipulated in BBL and as well installed in the building. During the course of inspection it has observed that the building/ premise is comprised of basement, ground & 03 upper floors but (Restaurant proposed at 2nd & 3rd floors only). Your request for FSC is rejected under Rule 35 (3) due to following shortcomings.

- 1 Facades are not properly sealed at each floor for compartmentation.
- 2 Terrace level fire pump capacity of 450lpm not provided.
- 3 Terrace level fire water tank capacity of 5,000ltr not provided.
- 4 Temporary structure seen at terrace level which needs to be removed.
- 5 Highly combustible material foam and plastic fencing use in all staircases second floor to terrace level which needs to be removed.

Keeping in view of above Fire Safety Certificate cannot be considered at this stage. You may apply again on form 'I' as stipulated in sub rule (2) 35 of rules, DFS Rules 2010 after compliance of the shortcoming mention above. The link for forms is as under available on [http://delhi.gov.in./wps/wcm/connect/doit fire/FIRE/Home/Forms](http://delhi.gov.in./wps/wcm/connect/doit%20fire/FIRE/Home/Forms).

Yours faithfully


15/2/2023

(Virendra Singh)
Chief Fire Officer
Ph. No. 011-23414000