

479

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/2023/WZ/ 99

Dated: 28/02/2023

To,

The Principal,
VSPK International School,
Sector-13, Rohini,
New Delhi-110085.

Sub: Issue of FSC in r/o VSPK International School, Sector-13, Rohini, New Delhi-110085.

Sir,

Kindly reference to online mail dated 12.01.2023, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **16.02.2023**, in presence of **Mr. Sandeep** to ascertain the availability and operability of the fire prevention and fire safety measures. The following shortcomings were observed:

1. 6.0 mtr roads all around the building are not provided.
2. Terrace pump of 900 lpm is not provided.
3. One standby pump capacity of 2280 lpm not provided.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 it is advised the applicant to apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/htt
p://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms

Yours faithfully


(In Charge)
DIRECTOR

Ph; 011-23414000

Bk
04