



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/BNQT/2023/NDZ/ 50

Dated: 01/03/2023

To,

The Authorized Signatory,
Silver Line Banquet Hall, D-58,
Dilshad Colony Shahdara,
Delhi-110095.

Subject:- FSC in r/o Silver Line Banquet Hall, D-58E Dilshad Colony Shahdara Delhi-110095.

Sir,

This has a reference to your e-mail ID silverlinebanquet@gmail.com Dated 17/02/2023, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 17/02/2023 in the presence of Sh. Aman Gupta and observed that building comprised of Basement, Stilt, Ground, First & Second floor only.

Following shortcomings were observed during time of inspection :

1. 2.0 meters wide doors are not provided.
2. Fire check doors not provided as marked in the plan.
3. Sealing of electrical shafts are not provided.
4. Detector system provided but not functional.
5. Exit Signages/Lift Signages not provided.
6. Fire Pumps are not on positive suction.
7. Fire Fighting system is also not on auto mode.
8. Measurement of underground tank is also required.
9. Doors on ground and terrace are not opening as per UBBL-2016.
10. Pressurization of lift shaft/staircase/lift lobbies not provided.
11. Staircases serving to basement are not segregated.

Keeping in view of above shortcomings, the application for issuance of Fire Safety Certificate can not be considered at this stage. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier. The Licensing Authority / Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Signature)
o/c
e
(ATEL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Dy. Health Officer, MCD (Health Deptt.), Shadhra (North Zone), MCD Building, Near Shyam Lal college, Shahdara, Delhi-110032. :- for information in r/o letter no. 215 dated 21/11/2022