



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75  
आज़ादी का  
अमृत महोत्सव

No. F6 /DFS/MS/Industrial/SZ/2023 / 516

Dated: 15/03/2023

To,

The Konzept Car India Private Limited,  
Plot no. D-29, Okhla Industrial Area, Phase- I,  
New Delhi-110020.

**Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Plot No. D-29, Okhla Industrial Area, Phase- I, New Delhi-110020.**

Sir,

This has reference to the your email dated 16.02.2023 on the subject cited above, it is informed that the said building was inspected by a team of officers concerned of this department on 04.05.2023 in the presence of Mr. Sunder Bisht (Manager) and it was observed that the building is comprised of Basements + Stilt + Ground + 02 upper floors. During the inspection following shortcomings were observed:

1. Fire check door (FCD) found removed.
2. Automatic Fire Detection and Alarm System (ADAS) found not functional.
3. Sprinkler outlets found removed at some places.
4. Diesel pump found removed.
5. Fire pumps not in auto mode.
6. Vehicle lift water curtains found removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

Copy to:-

The Executive Engineer (Building), South DMC, Jal Vihar, Lajpat Nagar, New Delhi-24.