



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6 /DFS/MS/Auditorium/SZ/2023 / 538

Dated: 17/03/2023

To,

The Joint Commissioner of Police,
Office of Joint commissioner of Police: Licensing,
1st Floor, P S Defense Colony, New Delhi.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Auditorium Building located at Chinmaya Mission, 89, Lodhi Road, New Delhi-03.

Sir,

with reference to the letter no.1093-98/Joint CP/Lic.(Amst.) dated 22.12.2022 on the subject cited above, it is informed that the said building was inspected by Assistant Divisional Officer (M. Road) from this department on 10.03.2023 in the presence of Manager and it was observed that the building is comprised of Basements + Ground + 02 upper floors. During the inspection the following shortcomings were observed:

1. Proper ventilation provisions in basement and alternate staircase at 2nd floor must be ensured.
2. Sprinklers to be extended in the service area of basement.
3. Auto starting of fire pumps must be provided.

In view of above shortcomings, the application for renewal for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)
Director

Delhi Fire Service

Copy to:-

The Licensee, M/s Auditorium Building located at Chinmaya Mission, 89, Lodhi Road, New Delhi-03.