

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6 /DFS/MS/GH/2023/SZ/ 139  
To

Dated: 21/03/2023

The Joint Commissioner of Police,  
Lic/Branch, 1<sup>st</sup> Floor, PS Defence Colony,  
New Delhi 110049.

Sub: - Regarding issuance of Fire Safety Certificate in r/o M/s Emblem Suites at Plot No A- 219,  
Kh. No 423, Road No- 06, Anadi of Extended Lal Dora Village, Mahipalpur New Delhi-  
110037

Sir,

This has reference with MHA Portal ID 2023021602152 dated 16/02/2023, on the subject cited above. In this regard it is to inform you that the above mentioned premise was visited by the officer concerned of this department and observed that the building is comprised of Basement, ground and five upper floors. The height of the building is shown on MHA portal ID 2023021602152 is 14.92 mtr, which seems to be wrong.

In this regard, the party may please be advised to submit these following documents to this department to ensure proper implementation of fire prevention & fire safety measures as applicable under Rule 33 of DFS-2010 the said premise/building.

1. Sanctioned/ Completion plans.
2. As built plan through building/local Authority, if sanctioned/Completion plans are not available.
3. Initial date of operation of Occupancy in this building.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to:-

1. The Executive Engineer (Bldg) MCD, Green Park Zone, Aurobindo Marg, New Delhi 110016.