



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7
आजादी का
अमृत महोत्सव

No. F.6/DFS/MS/EH/WZ/2023/ 148

Dated 23/03/2023

To,

The Joint Commissioner of Police,
Licensing unit, 1st Floor,
Police Station Defense Colony, New Delhi.

Sub.- Regarding issuance of Fire Safety Certificate in r/o M/s. Chaska Restaurant located at Property No. G-5, G-5A, G-6, G-7, G-8, G-9, G-10 at Ground Floor, F2, F3 at First Floor, S2, S3 at 2nd Floor, Plot No. A, Ground Floor, Maya Complex, GU Block, Pitampura, New Delhi- 110034.

Sir,


This is in reference to the online application received through MHA portal vide ID-2023022302496 on the subject cited above. In this connection it is to inform you that the eating house was inspected by the officer concerned of this department on 10.03.2023 in the presence of Sh. Kumar to check the provisioning of fire safety measures in the said restaurant.

During inspection, it was observed that the restaurant is running at ground, first & second floor in a building comprised of ground plus three upper floors. Fire safety arrangements such as fire extinguishers, down comer, first aid hose reel, terrace pump, overhead water tank etc. found provided. However, following shortcomings were observed: -

1. The two main staircases having width 2.0 & 1.5 mts have common entrance at 2nd Floor.
2. Exit signages are not provided at some places.
3. As built plan of First and Second Floors of the restaurant are not uploaded.
4. Terrace fire pump was not on auto mode.
5. Seating & kitchen on terrace floor shall be removed.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/occupier.

Yours faithfully


(Atul Garg)
Director

Copy to:

1. The Owner/occupier, M/s. Chaska Restaurant, Plot No. A, Ground Floor, Maya Complex, GU Block, Pitampura, New Delhi- 110034.
2. The Deputy Health Officer, Keshavpuram Zone, Delhi Municipal Corporation, Public Health Department, A-1 Block, Keshavpuram, Delhi- 110035.

EST/578
27/02/2023

MSCC

27/2

PP's please