



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/CNG/NDZ/2023/ 614

Dated: 24/03/2023

To

Sh. Ajay Khatri
DGM (Fire & Safety), IGI Bhawan,
Plot No. 4, Community Centre,
R.K. Puram Sec-9, New Delhi-22.

Sub: Regarding renewal of Fire Safety Certificate in respect of **M/s Metcalfe House CNG Station, Delhi.**

Sir,

This has reference to letter no.IGI/F&S/2023/15/17/1 dated 28.02.2023 on the subject cited above. It is to inform you that the CNG Station was inspected by the officer concerned of this department on 14.03.2023 in the presence Mr. Anil (Manager) and it was observed that building is comprised of ground floor only. During inspection, following shortcomings were observed:

1. Fire extinguisher are due for refilling.
2. "No Smoking" sign board not provided.
3. Foam trolley found not working.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

The applicant is requested to rectify the shortcomings at the earliest for further action.

Yours faithfully,

(Atul Garg)
Director

Delhi Fire Service
Tel: 011-23414000

01/03/23