

418



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No: F.6/DFS/MS/School/2023/SZ /123

Dated: 20/03/2023

To,  
The Manager,  
New Ring Midways Public School at E-109, Nanhey Park,,  
Uttam Nagar, New Delhi-110059.

**Sub:** - Regarding issuance of Fire Safety Certificate in r/o New Ring Midways Public School at E-109, Nanhey Park, Uttam Nagar, New Delhi-110059.

Sir,

Please refer to your letter No. MISC./NRPMS/AR/2022 Dated- 15/02/2023 on the subject cited above. In this regard, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 06/03/2023 to see the compliance of the requisite fire safety measures. Sh. Mahesh (Manager) was present and it was observed that the school building is comprised of Two Blocks Old block having ground plus two upper floors & New Block having ground plus three upper floors and have following shortcomings.

1. Both staircases of 1.5 m wide shall be provided in New block.
2. First aid Hose reel provided in old block but not functional & in New block First aid hose reel is not provided.
3. Fire pump having 450 lpm output at 40 m head provided in old block but not functional & in New block Fire pump 450 lpm not provided.
4. Overhead tank capacity 10,000 ltrs not provided in New block.
5. Exit Signage's provided but not sufficient.

In view of above, the school building cannot be considered for grant of fire safety certificate at this stage Therefore you are suggested to rectify the above said shortcomings under the intimation to this department for further course of action.

Yours Faithfully,

  
(Atul Garg)  
Director  
Delhi Fire Service  
9/4/23

Copy:-

The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.