आज़ादी का अमृत महोत्सव

463

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/GH/2023/ 133 Dated 21/03/2023

To

The Joint Commissioner of Police / Lic-Branch
1st floor, Police Station,
Defence Colony, New Delhi 110049

Sub: - Regarding issuance of fire safety certificate in r/o M/s Oscar Guest House at C–2/11, Safdarjung Development Area, Hauz Khas, New Delhi-110016

Sir,

This has reference to your MHA Portal ID 2022121421343 dated 17-01-2023 on the subject cited above. In this connection this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 03/03/2023 in the presence of Mr. Inder Mohan Singh to verify the fire safety arrangements as stipulated in NBC Part 4 and as well installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1 Fire check doors not provided in front side staircase as per clause 7.31 of UBBL 2016.
2 Smoke management system not provided in the upper floor as per clause 7.31 of UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE