



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No.F.6/DFS/MS/School/2023/NDZ/ 128

Dated:- 20/03/2023

To,

The Executive Engineer (E)
Delhi Tourism & Transportation Development Corporation Ltd.
Srinivaspuri, Lajpat Nagar
Near Cammbridge School, Ring Road,
New Delhi-110065

Subject:- Regarding issuance of Fire Safety Certificate in r/o of Rajkiya Sarvodaya Vidyalaya located at Shastri Park, Delhi-110053.

Sir,

With reference to your letter No. 23(03)/DTTDC/Engg./EE(E)/2022-23/453 dated 02/12/2022 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Sh. R.K. Sharma, Estate Manger of the school on dated 10/03/2023. The following points/shortcomings were noticed in the building which is comprised of ground plus two upper floors.

1. First Aid Hose Reel provided but not functional.
2. Fire pump having 450 LPM output with 40 meter head provided but not functional.
3. Auto starting system of pump not provided.
4. Over Head tank 10,000 liter not provided.
5. Exit signages not provided.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours faithfully,

(XUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. The Joint Director of Education (Land & Estate),
Director of Education, Lucknow Road, Delhi-110054
2. The Principal,
Rajkiya Sarvodaya Vidyalaya located at Shastri Park, Delhi-110053