



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

C/95

No. F6/DFS/MS/School/SZ/2023/ 125

Dated: 20/03/2023

To,

The Head of School,
Sachdeva Global School,
Sector-18A, Phase-II, Dwarka,
New Delhi-110078.

Sub: - Regarding renewal of "Fire Safety Certificate" from fire safety point of view in r/o Sachdeva Global School, Sector-18A, Phase-II, Dwarka, New Delhi-110078.

Sir,

Please refer to your letter No. SGS/Admin/9/2023, dated 28.02.2023 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school building on 13.03.2023 to verify the existing fire safety arrangements. At the time of inspection Sh. Pankaj Bhatnagar, Administrator of the school was present.

It was observed that the school building comprises of basement, ground plus three upper floors. The following shortcomings from fire safety point of view were observed :-

1. Fire check doors in two staircases in basement floor found removed.
2. Fire pumps on terrace are not on auto mode.
3. 5000 liters overhead tank provided at terrace against the requirement of 10,000 liters for firefighting systems.
4. Exit signs not provided at all exit and escape routs at appropriate locations.
5. Floor marking has not done in escape routs.

In view of above, the renewal of fire safety certificate cannot be considered at this stage.

Yours faithfully

(Yuri Gang)
Director

Delhi Fire Service

otc
E

Copy to:-

The Director of Education,
G.N.C.T. of Delhi, Old Secretariat,
New Delhi.