



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No.F.6/DFS/MS/EH/2023/NDZ/ 141

Dated: 20/03/2023

To,

The Manager

Urban Punjab Restaurant,

Shop No. G 1, G 5, G 7, G 10, G 12, G 13 & G 14, Pankaj Plaza, Karkardooma Community Centre, Delhi-110092.

Subject: -Regarding issuance of Fire Safety Certificate in r/o Urban Punjab Restaurant located at at Shop No. G 1, G 5, G 7, G 10, G 12, G 13 & G 14, Pankaj Plaza, Karkardooma Community Centre, Delhi-110092.

Sir,

This is in reference to your MHA ID No. 2023021402022 dated 17/02/2023 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department have carried out the inspection of the above mentioned premises on dated 02/03/2023 from fire safety point of view in presence of Mr. Parvinder Pal. During the course of inspection, following shortcomings were noticed in the building which is comprised of ground plus two upper floors. Eating House is running on ground floor only.

1. MOEFA not provided.
2. Exit signage not provided.

In view of above, the building can not be considered for issue of Fire Safety Certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

The Joint Commissioner (Lic.)

1st floor Police Station Defence Colony, New Delhi

MHA ID No. 2023021402022