



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/ESS/MS/2023/Indl./ 628

Dated 27/03/2023

To

Sh. Vikas Sehgal
Plot No-64, Rajasthani Udyog Nagar,
Karnal Road, Industrial Area, Jahangirpuri, Delhi-33.

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s Sehgal Industrial Works at Plot No-64, Rajasthani Udyog Nagar, Karnal Road, Industrial Area, Jahangirpuri, Delhi-110033.

Sir,

Kindly refer to your letter received through online e-mail dated 14.03.2023 on the subject cited above. In this connection this is to inform you the above mentioned site was visited by the officer concerned of this department on 16.03.2023 to verify the fire safety arrangements installed in the building as per issued fire safety recommendations vide letter of even no. 31 dated 24.01.2019. At the time of inspection Sh. Vikas Sehgal (Owner) was also present at site. During the course of the inspection it is observed that the building is comprised of basement, ground & two upper floors only. Your request for FSC is rejected under Rule 37 (3) due to following shortcomings.

1. Fire check doors found removed at some places.
2. Smoke ventilation systems found removed in basement.
3. Sprinkler systems provided in the basement & all upper floors but found not functional.
4. Exit & floors signage's found removed in the building.
5. Temporary structure seen at terrace level which is not shown on plan needs to be removed.

Keeping in view of above non-compliance of Fire Safety provisions, Fire Safety Certificate cannot be considered at this stage.

Yours faithfully

(Ajul Garg)
Director

Ph. No. 011-23414000

o/c

Copy to:-

1. The Dy. Commissioner of Factory licensing, SDMC 3rd, Floor, Civic Centre Minto Road, Delhi-110002.