



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI- 110001**

No. F.6/DFS/MS/2023/SZ/ 619  
To

Dated: 27/03/2023

Mr. Narender Kumar Gaur (Fire Officer),  
New Delhi Municipal Council,  
Palika Kendra, New Delhi 110001

Sub: Issuance of NOC in r/o M/s Palika Bhawan at R.K Puram Sector-13, New Delhi

Sir,

This has reference to your Email of dated 25/02/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 13/03/2023 in the presence of Mr. Narender Kumar Gaur (Fire Officer), to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. There are 03 staircases from ground to 2<sup>nd</sup> floors- 03 nos, 2<sup>nd</sup> F to 6<sup>th</sup> floors 02 nos, and 01 staircase from 6<sup>th</sup> floor to terrace level found block and locked.
2. Sealing of shift not done.
3. The Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

0/0