

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/Mixed/2023/SZ/ 620

Dated: 27/03/2023

To

Mr. Narender Kumar Gaur (Fire Officer),
New Delhi Municipal Council,
Palika Kendra, New Delhi 110001

Sub: Regarding issuance of NOC in r/o M/s Ansal Plaza, Shopping Arcades located at
Hudco Place, Pinjra Pole, Andrews Ganj, New Delhi

Sir,

This has reference to your outdoor diary no 12103 dated 10/03/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 17/03/2023 in the presence of Mr. Mukesh Sharma (Fire Officer) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Fire check doors found removed / damages.
2. Smoke management system provided but found non functional.
3. First aid hose reel provided but found non functional.
4. Automatic sprinkler system provided but found non functional.
5. The MOEFA system found removed.
6. Automatic Sprinkler System provided but found non functional.
7. Internal hydrant and yard hydrant provided but found non functional.
8. Fire fighting pumps are not on auto mode.
9. Exit Signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

o/uf